

# OPERATING MANUAL

## Overhead Stirrer

WB2000-C



**WIGGENS**  
THE MAGIC MOTION

**WIGGENS GmbH**

Gässlesweg 22-24, 75334 Straubenhardt,  
Germany

Tel.: 0049 7248 4529088

**Wiggins Co., Ltd.**

Room 426, Hall A, Office Building M8, No.1  
Jiuxianqiao East Road, Chaoyang District,  
Beijing 100015, China

Tel: +86 400-809-2068

Fax: +86 400-809-2068-112

info@ wiggins.com

www.wiggins.com

## Congratulations!

You have made an excellent choice.

WIGGENS thanks you for the trust you have placed in us.

This operating manual has been designed to help you gain an understanding of the operation and possible applications of our instruments. For optimal utilization of all functions, we recommend that you thoroughly study this manual prior to beginning operation.

## Unpacking and Inspecting

Please unpack the device carefully. Check that the package is right-side-up and then open it. Check that model of the product is one that you ordered. Check that there is no damage. If there is any damage, file a damage claim with the carrier. In the case of any damage a damage report should be requested immediately. These instructions must be followed fully for us to guarantee our full support of your claim for protecting against loss from concealed damage. The form required for filing such a claim will be provided by the carrier.

Changes without prior notification reserved

**Important:** keep operating manual for future use

# Content

1. Intended Use.....	4
2. Operator Responsibility.....	4
2.1. Disposal.....	5
2.2. CE Conformity.....	5
2.3. Technical Specifications.....	6
3. Safety Instructions.....	7
3.1. Explanation of Safety Notes.....	7
3.2. For Your Protection .....	7
3.3. For protection of the equipment .....	10
4. Operating Procedures .....	10
4.1. Environmental Operating Conditions .....	10
4.2. Installation.....	10
4.2.1. Installing the Overhead Stirrer .....	11
4.2.2. Impeller Attachment.....	12
4.2.3. The dimensions of the Overhead stirrer (WB2000-C).....	12
4.3. Operation .....	13
4.3.1. Operation of the WB2000-C.....	13
4.3.2. Functional Elements .....	13
4.3.3. Safety and Servo Control.....	14
5. Cleaning and Maintenance .....	15
5.1. Routine Cleaning .....	15
5.2. Maintenance.....	16
6. Transport and Storage .....	17
7. Accessories and Spare Parts.....	17
7.1 Stainless Steel Impeller.....	17
7.2 Stirring Seals.....	19
7.3 Stand.....	19
8. Service .....	21
8.1. Trouble-Shooting .....	21
8.2. Warranty.....	22
8.3. Contact /Technical Service.....	22

## 1. Intended Use

Fulfilling its principle task of a reliable and accurate stirring process, the Overhead Stirrer WB2000-C also incorporates a remote control function by connecting the unit to a computer via an RS-232 cable. It is also equipped with digital analog input/output ports and a foot pedal port for various applications. This allows for wide applications to stir, such as, stirring in reaction systems, stirring in processes which need remote control, or stirring processes that are linked to other equipment. It is also suitable for low speed stirring and very sensitive stirring processes.

The brushless DC motor provides stable and accurate stirring. It is easy to use and suitable for small batches, long-term experiments and programmable operations. Voltage fluctuations are not a concern due to the universal power supply which offers 100-240 volts.

Furthermore, the digital display, sealed housing and overload protection are standard WIGGENS features!

## 2. Operator Responsibility

### Use

For mixing/stirring liquids by various stirring tools.

### Range of use (indoor use only)

- Laboratories
- Pharmacies
- Schools
- Universities

This instrument is suitable for use in all areas except:

- Residential areas
- Areas that are connected directly to a low-voltage supply network that also supplies

Residential areas

The safety of the user cannot be guaranteed:

- If the instrument is operated with accessories that are not supplied or recommended by the manufacturer
- If the instrument is operated improperly or contrary to the manufacture's specifications
- If the instrument or the printed circuit board are modified by third parties.

The products of WIGGENS ensure safe operation when installed, operated, and maintained according to common safety regulations. This section explains the potential dangers that may arise when operating the instrument and also specifies the most important safety precautions to preclude these dangers as far as possible.

- The operator is responsible for the qualification of the personnel operating the instrument.
- The personnel operating the instrument should be regularly instructed about the dangers involved with their job activities as well as measures to avert these dangers.
- Make sure all persons tasked with operating, installing, and maintaining the instrument have read and understand

the safety information and operating instructions.

- When using hazardous materials or materials that could become hazardous, the instrument may be operated only by persons who are absolutely familiar with these materials and the instrument. These persons must be fully aware of possible risks.
- Only qualified personnel are authorized to perform configuration, installation, maintenance and repairs of the instrument.
- Routine operation can also be carried out by untrained personnel who should however be instructed by trained personnel.

If you have any questions concerning the operation of your instrument or the information in this manual, please contact us!

2.1. Disposal



At the end of its service life the instrument is to be disposed of in accordance with the local regulations specified for the disposal of electronic industry waste in an environmentally friendly manner.

2.2. CE Conformity



The products described in the operating instructions conform to the requirements of the following European guidelines:

Low voltage regulations with respect to legal harmonization of the member countries concerning electric devices for use within certain voltage limits.

EMC guideline with respect to legal harmonization of the member countries concerning electromagnetic compatibility.

<b>APPROVALS</b> European	EN61326-1: 2013, 2014/30/EU EN61010-1: 2010, 2014/35/EU EN50581: 2012, 2011/65/EU
------------------------------	---

## 2.3. Technical Specifications

Model	WB2000-C	
Speed Range	20-2000 rpm	
Display / Control Mode	LCD Digital Display / On-Touch Control	
LCD Display Accuracy	±10 rpm or 1% of reading, 4 digit display	
Maximum Torque	70 N-cm, (100 in-oz)	
Maximum Viscosity	20000 mPa-s (20000cps)	
Maximum Capacity	50L	
Chuck range max. diameter(mm)	10	
Clockwise and Counter-Clockwise Mixing	Yes	
Input / Output Power	AC 100-240 V, 50/60 Hz, 70VA (the supplied WIGGENS power supply must be used)	
Output Voltage From Power Supply to Stirrer	DC 24V	
Output Current from Power Supply to Stirrer	3.0 A	
Mechanical Output Power	1/15 hp, 50 W, (Brushless DC Motor)	
Weight	Stirrer	3.5kg (7.7 lbs)
	Power Supply	0.5kg (1.1 lbs)
Combined Housing	Splash Proof	
Operation Panel	Waterproof, Chemical Resistant Polyester	
Power Cord Lengths	160 cm from Stirrer to Power Supply (DC)	
	150 cm from Power Supply to Wall (AC)	
Adjustable Chuck	Fits Onto Output Shaft Of Stirrer, Adjustable up to 10 mm	
Analog Input	0-20 mA and 0-10 V	
Analog Output	0-5 V	
RS232 Output	Available	
Foot Pedal Output	Available	
Order No.	100500	

All measurements have been carried out at the stated voltage, frequency, and an ambient temperature of 25°C.

Technical changes without prior notification reserved.






WIGGENS Order Numbers consist of the Basic Order Number (BON) and the Order Number Addition (ONA) which explains different characteristics of the product that can vary from country to country. Order Numbers as stated on the product label and box label are stated as Full Order Numbers (FON), consisting of the BON followed by the ONA. For a full explanation of the ONA of your product, please ask your local WIGGENS support or refer to the Order Number Guide in the *WIGGENS* General Catalog.


## 3. Safety Instructions

### 3.1. Explanation of Safety Notes

In addition to the safety warnings listed, warnings are posted throughout the operating manual. These warnings are designated by an exclamation mark inside an equilateral triangle. "Warning of a dangerous situation (Attention! Please follow the documentation)."

Symbol	Additional term / Description
	The danger is classified using a signal word. Read and follow these important instructions for averting dangers.
	<b>Warning!</b> Describes a <b>possibly</b> highly dangerous situation. If these instructions are not followed, serious injury and danger to life could result.
	<b>Caution!</b> Describes a <b>possibly</b> dangerous situation. If this is not avoided, slight or minor injuries could result. A warning of possible property damage may also be contained in the text.
	<b>Notice!</b> Describes a <b>possibly</b> harmful situation. If this is not avoided, the product or anything in its surroundings can be damaged.
	<b>Note!</b> Draws attention to something special.
	<b>Important!</b> Indicates usage tips and other useful information.

### 3.2. For Your Protection

- Make sure you read and understand all instructions and safety precautions listed in this manual before installing or operating your instrument.
- Keep the operation instructions in a place where they can be accessed by everyone
-  **Warning!** Because the options for combining products, tools, stirring vessel, experiment and medium are nearly endless, user safety cannot be ensured simply with design requirements on the part of the product. For this reason, it may become necessary for users to take other precautionary safety measures. For example, glass device or

other stirring vessels that are sensitive to mechanical stress can be damaged or shattered by an imbalance, increasing the speed too quickly or too little distance between the stirring element and the stirring vessel. Users can suffer serious injury from glass breakage or from the freely rotating stirring element.

- Uncontrolled reactions can be triggered by mixing the heated material insufficiently or by the energy generated by selecting a speed that is too high. In case of these and other increased operational hazards, users must take additional appropriate safety precautions (e.g. shatter protection). In any case, when using critical or hazardous materials in your processes, WIGGENS recommends to use additional appropriate measures to ensure safety in the experiment. For example, users can implement measures that inhibit fire or explosions or comprehensive monitoring equipment.
- Make sure the product is checked for proper condition regularly (depending on the conditions of use). Regularly check (at least every 2 months) the proper condition of the mandatory, warning, prohibition and safety labels.
- Connect the instrument to a power socket with earthing contact (PE-protective earth)!
- The power supply plug serves as a safe disconnecting device from the line and must always be easily accessible.
- Do not stay in the area below the instrument.
- Never operate damaged equipment.



- **Warning!** Never operate instruments with damaged mains power cables.
- Observe all warning labels.
- Never remove warning labels.
- Repairs are to be carried out only by qualified service personnel
- Always turn off the instrument and disconnect the mains cable from the power source before performing any service or maintenance procedures, or before moving the instrument.



- **Warning!** This is not an explosion proof stirrer. Do not use with any highly flammable or explosive materials.



- **Warning!** The stirrer must be securely fixed to a stable support, mounted to a stand using a heavy duty clamp, which must be provided by WIGGENS. If other stands or clamps are used, ensure that they are stable so that it will not fall down.









- **Warning!** Spinning paddles or impellers can cause serious personal injuries. Operators must take extreme care and good judgment when mixing at any speed. All mixing paddles and impellers must be in good condition with straight shafts. If the stirrer vibrates at high speed, check the paddle shaft for damage and repair or replace it.
- Also, extreme care must be taken when mixing chemicals, to ensure that no chemicals are splashed outside the mixing vessel, and when changing to faster mixing speeds.



- **Warning!** Ensure that the mixing impeller does not contact the containment vessel.
- Keep the unit dry and do not immerse any part, except the mixing paddle into any liquids.
- Protect yourself from splashes.



-  **Warning!** Ensure that no loose clothing, jewelry, or hairs are entangled in any rotating parts. A fast spinning chuck can cause injury to the operator.
- Only process media that will not react dangerously to the extra energy produced through processing. This also applies to any extra energy produced in other ways, e.g. through light irradiation.
- Process pathogenic materials only in closed vessels under a suitable fume hood.
- When in an emergency, disconnect the main power plug.
- The voltage stated on the type plate must correspond to the mains voltage.
- Please observe the permitted speed for the stirring element. Never set higher speed.
-  **Warning!** The operation of a free rotating shaft end is dangerous. Therefore, for safety reason, only insert through the stirring tool over the upper edge of housing at standstill.
-  **Warning!** Wear your personal protective equipment in accordance with the hazard category of the medium to be processed, otherwise there is a risk of:
  - - splashing of liquids
  - - Projectile parts
  - - Body parts, hair, clothing and jewelry getting caught.
-  **Warning!** Beware of the risk of:
  - - Flammable materials
  - - Glass breakage as a result of mechanical shaking power.
- Reduce the speed if:
  - - The medium splashes out of the vessel because the speed is too high
  - - The instrument is not running smoothly
  - - The instrument begins to move around because of dynamic forces
  - - An error occurs.
-  **Warning!** Do not touch rotating parts during operation!
-  **Warning!** There may be electrostatic activity between the medium and the output shaft which could cause a direct danger.
- After an interruption in the power supply or a mechanical interruption during a stirring process, the unit does not restart automatically.
- It is important to note that the surfaces of the motor (cooling fins) and certain parts of the bearing may get very hot during operation.
- Avoid knocking and impacting on the lower end of the shaft and the chuck gear teeth. Even minor, invisible damage can lead to imbalance and uneven shaft action
- Imbalance of the output shaft, the chuck and in particular the stirring tools can lead to uncontrolled resonant vibrational behavior of the instrument and the whole assembly. Glass apparatus and stirrer containers can be

damaged or shattered by this. It can cause injury to the operator, also can damage the rotating stirring tool. In this case exchange the stirring tool for one without imbalance or remedy the cause of the imbalance. If there is still imbalance, return it to the dealer or the manufacturer along with a description of the fault.

- If the instrument is operated too long in overload or if the ambient temperature is too high, the instrument switches off permanently.

### 3.3. For protection of the equipment

All operators must be familiar with the stirrer and should read this entire manual.

- You have received a product designed for industrial and experimental use. Nevertheless, avoid strikes to the housing, vibrations, damage to the operating-element panel, and contamination.
- Make sure that the mains power supply has low impedance to avoid any negative effects on instruments being operated on the same mains.
- Do not expose the unit to sunlight
- Sudden drops may cause damage in the interior of the instrument.
- Transport the instrument with care.
- Press the power button to interrupt the stirrer, rather than disconnect the main power plug directly.

## 4. Operating Procedures

### 4.1. Environmental Operating Conditions

The overhead stirrer must operate in the following conditions:

- Indoors
- Altitudes up to 2000 meters
- Temperatures from +5°C to +40°C
- Maximum relative humidity 80% for temperatures up to +31°C, linear decrease down to 50% relative humidity at a temperature of +40°C
- Max. mains fluctuation of  $\pm 10\%$  are permissible
- Overvoltage category II

### 4.2. Installation

Place the stirrer on a stable, flat surface and proper environment for operation.



#### Note!

The hollow shaft allows the impeller shaft to come through the top of the stirrer if necessary!

#### 4.2.1. Installing the Overhead Stirrer

##### Installation Steps



- Installing the Support Bar



- Clamp the stirrer to a *WIGGENS* stand on a stable level surface.
- Insert the impeller shaft into the open chuck and adjust the impeller to the desired height.



- Connect the stirrer to the *WIGGENS* power supply.
- Connect the power supply to a power socket with earthing contact.

### 4.2.2. Impeller Attachment

- Loosen the clamp connected to the support bar and raise the stirring unit to the far end of the support bar
- Tighten the clamp again
- Use the chuck key to open up the chuck inlet
- Insert the impeller shaft into the open chuck and adjust the impeller to the desired height. The hollow housing allows the impeller shaft to come through the top of the stirrer if necessary.
- Tighten the chuck manually until the impeller shaft hangs loosely in the chuck
- Use the chuck key to gradually tighten the chuck from all sides and make sure that the impeller is as vertical as possible.
- If necessary adjust the height of the stirrer again by loosening the clamp connected to the support bar. Make sure to tighten the clamp as much as possible after adjusting the height and before operating the unit.

#### CAUTION!



- Operating a freely rotating impeller shaft through the top of the stirrer is not safe. Do not allow the impeller shaft to touch or extend through the rubber gasket while the motor is powered on, the gasket is for sealing purposes only. Tighten the chucks outer ring by hand and then fasten with the chuck key.
- If the chuck is removed without the supplier's permission, any damage will be excluded from the warranty.

### 4.2.3. The dimensions of the Overhead stirrer (WB2000-C)






4.3. Operation



4.3.1. Operation of the WB2000-C



1. Housing
2. On / Off-Button
3. Increase Button
4. Decrease Button
5. Chuck
6. Reverse Button
7. Menu Button
8. LED Power Light
9. LCD Display

4.3.2. Functional Elements

	<b>On / Off – Button</b> Start or stop the stirrer.
	<b>Menu Button</b> Select between the speed setting, and the control mode setting
	<b>Increase Button</b> When in speed setting mode, press the button to set the speed rate, press to increase 10 rpm every time, press and hold to increase the value faster. When in control mode setting, press the button to select between the following modes: <ul style="list-style-type: none"><li>● LOCAL: Direct control via the on-touch buttons.</li><li>● ANA V: External control via analog voltage. The voltage range permissible is 0~10V (speed can't be set by the keypad in this mode)</li><li>● ANA I: External control via analog current. The current range permissible is 0~20mA (speed can't be set by the keypad in this mode)</li><li>● FOOT: Control via foot pedal (speed can't be set by the keypad in this mode)</li><li>● REMOTE: Remote control via USB interface</li></ul>

	<p><b>Decrease Button</b></p> <p>When in the LOCAL mode, press the button to set the rate, press to decrease 10RPM every time, press and hold to decrease the value faster.</p> <p>When in control mode setting, press the button to select between the modes mentioned under the Increase Button</p> <p>When in timer setting, press the button to select between the two modes mentioned under the Increase Button</p>
	<p><b>Reverse Button</b></p> <p>Press this button to change the stirring direction. This can only be done when the stirrer is in off-mode. The stirring direction can be monitored in the LCD display: ACW for clockwise stirring and CCW for counter-clockwise stirring.</p>



### CAUTION!

Make sure the stirrer is securely mounted as specified in the installation instructions. Ensure the mixing paddle or impeller is securely attached to the desired position. The stirrer is now ready for use to mix liquids and liquid/solid solutions. Appropriate impeller and container specifications must be determined by the operator, ensuring that all safety instructions are followed.

#### 4.3.3. Safety and Servo Control

The WB2000-C stirrer employs a memory function. When switching on and starting the stirrer, the speed used is the same as set at the last operation.

The WB2000-C incorporates a "soft start" function. When starting the stirrer, increasing or decreasing the stirring speed, or using the reverse function, the speed ramps smoothly from the current speed to the new set speed. This has the advantage of protecting fragile solutions from a abrupt speed increase, and prevents the stirrer from damage.

The WB2000-C incorporates feedback control. When the torque changes, e.g. by a change of viscosity in the solution, the stirrer motor adjusts the feedback accordingly in order to maintain the current speed.



### CAUTION!


If the torque is too heavy, it is necessary to reduce the weight of the load and to restart the stirrer.

Besides the press-button control, the WB2000-C can also be remotely controlled.

For remote control there are two operating methods:

## 1. Analog Input / Output Control:


Use a 0-20mA or 0-10V signal to drive the stirrer. Please refer to the pin assignment as following:



- 1: Input 0-20mA (0-2000 RPM)
- 2: Input 0-10V (0-2000 RPM)
- 3: Input ground
- 4: Output 0-5V (0-2000 RPM)
- 5: Input foot pedal
- 6: Output ground

## 2. RS-232 Control:

The stirrer can be controlled by connecting a computer via the RS-232 cable. Free software is provided for RS-232. Please refer to the software operating instruction for the correct application.



- 1: TXD Sending
- 2: RXD Receiving
- 3: GND Ground signal

## CAUTION!



WB2000-C adopts servo motor control and soft starting safety control. Even in heavy load situations it can still be able to maintain the set speed. When the instrument is started, the last used speed will be displayed on the LCD screen.

The stirring direction can only be changed when the stirring function is turned off.


If the torque is too heavy, it is necessary to reduce the weight of the load and to restart the stirrer.

## 5. Cleaning and Maintenance

### 5.1. Routine Cleaning

The device is maintenance-free.

#### Cleaning



For cleaning disconnect the main plug.

Only use cleansing agents which have been recommended by WIGGENS

Use to remove:

Dyes isopropyl alcohol

Construction materials isopropyl alcohol/water containing surfactant

Cosmetics isopropyl alcohol/water containing surfactant

Foodstuffs water containing surfactant

Fuels water containing surfactant

- Do not allow moisture to get into the appliance when cleaning.
- Wear protective gloves when cleaning the devices.
- Before using another than the recommended method for cleaning or decontamination, the user must ascertain with WIGGENS that this method does not destroy the instrument



### Note:

Do not use chlorine bleach, chlorine-based cleanser, abrasives, ammonia, steel wool or scouring pads with metal content or similar harsh solvents or abrasives. These may damage the surface of the instrument.

## 5.2. Maintenance

Do not attempt to service or repair a WIGGENS overhead stirrer. If the overhead stirrer housing is opened the warranty becomes void. Contact WIGGENS for return authorization and return instructions.

Ordering spare parts

When ordering spare parts, please give:

- Machine type
- Manufacturing number, see type plate
- Item number and designation of the spare part.

### Repair

Please only send devices in for repair that have been cleaned and are free of materials which might present health hazards. For this, use the "certificate of compliance" form which you can obtain from WIGGENS. If your appliance requires repair, return it in its original packaging. Storage packaging is not sufficient when sending the device - also use appropriate transport packaging.



## 6. Transport and Storage

- Clean the overhead stirrer so that it is free from any materials which may be harmful to the health. Provide a material safety data sheet where appropriate.
- Place the overhead stirrer unit and its parts into the original packing or a container with necessary protection to prevent damage during transport. Seal the original packing or container with packing tape.
- Store the packed unit in a dry place.



### CAUTION!

Failure to clean, maintenance, and handle the stirrer as outlined can lead to damages or be harmful to the health.

## 7. Accessories and Spare Parts

### 7.1 Stainless Steel Impeller



**Pivoting Blade Impeller**  
Blade Heigh:18 mm

Rotor Ø( mm)	Shaft Ø(mm)	Lengt h(mm)	Oder No.
50	8	300	9603
50	8	400	9604
50	8	500	9605



**Straight 4-Blade Impeller**  
Blade Heigh:12 mm

50	8	300	9053
50	8	400	9054
50	8	500	9055
100	10	300	9056
100	10	400	9057
100	10	500	9058



**Straight 2-Blade Impeller**  
Blade Heigh:12 mm

Rotor Ø( mm)	Shaft Ø(mm)	Length (mm)	Oder No.
50	8	300	9703
50	8	400	9704
50	8	500	9705



**3-Hole Blade Impeller**

50	8	300	9403
50	8	400	9404
50	8	500	9405
100	10	300	9406
100	10	400	9407
100	10	500	9408



**6-Hole Blade Impeller**

50	8	300	9503
50	8	400	9504
50	8	500	9503
100	10	300	9506
100	10	400	9507
100	10	500	9508



**Propeller stirrers, 3 \_x blades**

Rotor Ø( mm)	Shaft Ø(mm)	Lengt h(mm)	Oder No.
50	8	300	9103
50	8	400	9104
50	8	500	9105
70	8	300	9109
70	8	400	9110
70	8	500	9111
100	10	300	9112
100	10	400	9113
100	10	500	9114
70	10	650	9111
100	10	800	9116



**Anchor Impeller**



**Pitched Leaf Impeller and Pitched Blade Impeller**

50	8	300	9003
50	8	400	9004
50	8	500	9005
100	8	300	9009
100	8	400	9010
100	8	500	9011
70	8	500	9012
100	10	650	9013
100	10	800	9014





**Centrifugal Impeller**  
Blade Heigh:10mm

Rotor Ø( mm)	Shaft Ø(mm)	Length (mm)	Oder No.
90/15	8	400	9210
90/15	8	500	9211
90/15	10	300	9212
90/15	10	400	9213
90/15	10	500	9214
90/15	10	650	9215




**Turbine Impeller**

70	8	500	9610
90	10	650	9611
140	10	800	9612
			
Radial Flow Impeller			
50	7	400	9030
50	8	400	9031

45	7	400	9025
65	7	400	9026
45	8	400	9025A
65	8	400	9026A
			
Multi-Purpose Impeller			
80	10	500	9020
120	10	500	9021

## 7.2 Stirring Seals

Model	Shaft Ø mm)	'A'Core	Height(mm) excl.joint	Guide Ø (mm)	Oder No.
	6	19/22	96	45	5.101.1.7
	6	24/40	96	45	5.102.7
	8	24/40	96	45	5.104.7
	10	24/40	96	45	5.105.7
	10	29/42	96	45	5.106.7
	12	29/42	110	55	5.108.7

## 7.3 Stand



Dimensions (W x D): 315X200mm  
Max. load: 5 kg

Model	Height(mm)
WF11	550
WF12	750
WF13	950



Dimensions (W x D): 315X200mm

Model	Height(mm)
WF11-D	550
WF12-D	750
WF13-D	950



Material: Aluminum, stainless steel  
Dimensions (W x D): 340X300mm

Model	Height(mm)
WH11-S	550
WH12-S	750
WH13-S	950



Material: Aluminum, stainless steel  
Dimensions (W x D): 340X300mm

Model	Height(mm)
WH11-D	550
WH12-D	750
WH13-D	950



For more information about Accessories please contact your local supplier



### CAUTION!

For safety and guarantee reasons only original accessory parts are to be used!

## 8. Service

### 8.1. Trouble-Shooting

Cause	Remedy
After switching on the unit, the display shows no light and the stirrer does not react to any input	<ol style="list-style-type: none"><li>1. Ensure that the mains electricity plug is plugged into a working socket outlet and check if the main switch is in the "on" position</li><li>2. Use a circuit meter to check if there is DC24V electricity running from the adapter output port</li><li>3. If the malfunction cannot be determined this way, please contact the WIGGENS support</li></ol>
After switching on the unit, the display lights up but shows the error message "OH"	Please contact the WIGGENS support



WIGGENS reserves the right to carry out technical modifications with repairs for providing improved performance of the instrument.

## 8.2. Warranty

In accordance with WIGGENS warranty conditions, the warranty period is 24 months. For claims under the warranty please contact your local dealer. You may also send the machine direct to our works, enclosing the delivery invoice and giving reasons for the claim. You will be liable for freight costs. The warranty does not cover wearing parts, nor does it apply to faults resulting from improper use or insufficient care and maintenance contrary to the instructions in this operating manual.

WIGGENS reserves the right to decide the validity of any warranty claim. In case of faults arising either due to faulty materials or workmanship, parts will be repaired or replaced free of charge.

Any other compensation claims, such as consumables, damages caused by corrosion or accidental breakage, are excluded from this guarantee.

This warranty may only be altered by a specifically published amendment. No individual has authorization to alter the provisions of this warranty policy or its amendments.

## 8.3. Contact /Technical Service

If your device is not working properly:

- ⇒ Please inform *WIGGENS* Instruments by using our contact information.  
You have contacted *WIGGENS* Instruments?
- ⇒ Copy and complete the Confirmation of condition of unit from these operating instructions.
- ⇒ Please repack the device appropriately for transport and send to *WIGGENS* Instruments together with the Confirmation of condition of unit.

### Our contact details

#### **WIGGENS GmbH**

Add: Gässlesweg 22-24, 75334 Straubenhardt, Germany

Tel.: 0049 7248 4529088

#### **Wiggins Co., Ltd.**

Room 426, Hall A, Office Building M8, No.1 Jiuxianqiao East Road, Chaoyang District, Beijing 100015, China

Tel: +86 400-809-2068

Fax: +86 400-809-2068-112

info@wiggins.com

service@wiggins.com

www.wiggins.com

## Confirmation of condition of unit

In the case of repair, copy and complete the Confirmation of condition of unit and send it to *WIGGENS* Instruments.

### 1. Details about the unit

Product number \_\_\_\_\_  
Serial number \_\_\_\_\_  
Reason for repair \_\_\_\_\_  
\_\_\_\_\_

### 2. Has the device been cleaned, decontaminated/sterilized?

Yes ☐ No ☐

### 3. Is the unit in a condition which does not represent any health threats for the staff of our service department?

Yes ☐ No ☐

If not, which substances has the unit come into contact with?

\_\_\_\_\_

### 4. Legally binding declaration

The customer is aware of being legally liable to *WIGGENS* Instruments for any damages arising from incomplete and incorrect information.

Date \_\_\_\_\_ Signature \_\_\_\_\_  
Company stamp \_\_\_\_\_

## Please Note

The shipper is responsible for the return of the goods in well-packed condition, suitable for the mode of transport.

### Sender information

Name \_\_\_\_\_  
Company \_\_\_\_\_  
Department, research group Street \_\_\_\_\_  
Zip code, city \_\_\_\_\_  
Country \_\_\_\_\_  
Phone \_\_\_\_\_  
E-mail \_\_\_\_\_



**WIGGENS GmbH**

Gässlesweg 22-24, 75334 Straubenhardt, Germany

Tel.: 0049 7248 4529088

**WIGGENS China**

Room 426, Hall A, Office Building M8, No.1 Jiuxianqiao East Road,  
Chaoyang District, Beijing 100015, China

Tel: +86 400-809-2068

Fax: +86 400-809-2068-112

[info@wiggens.com](mailto:info@wiggens.com)

[www.wiggens.com](http://www.wiggens.com)